


FMEA Builder & Quality Assessor ^{QDES}

Sign in to access the application

 Sign in with Google

— or use email —

[Sign In](#) [Create Account](#)

Email

Password



Sign In

[Forgot password?](#)



Developed by Kemal Dorak

www.qdes.org

Select AI models



Backend Configuration

Select Backend [?](#)

- Ollama
- LM Studio
- OpenAI
- Google Gemini
- Claude (Anthropic)

Anthropic API Key [?](#)



Enter your Anthropic API key to use Claude models.

Model



Temperature [?](#)

0.30

Max Tokens [?](#)

4096

Signed in as:

kemal.dorak@gmail.com

Sign Out

FMEA Builder & Quality Assessor

[Generate FMEA](#) [Assess FMEA Quality](#) [My Documents](#) [How to Use](#)

1. Upload FMEA Knowledge Sources

Upload specifications, standards, process flows, and historical data

200MB per file • PDF, DOCX, XLSX, TXT

2. Upload FMEA Template (Optional)

If no template is uploaded, a standard FMEA structure will be used automatically.

Upload your FMEA template (docx, pdf, txt, or xlsx) — optional

200MB per file • PDF, DOCX, TXT, XLSX

3. Describe the context (optional)

Add any special instructions such as business unit, risk scoring method, or stakeholders


Upload inputs

FMEA Builder & Quality Assessor

[Generate FMEA](#) [Assess FMEA Quality](#) [My Documents](#) [How to Use](#)

1. Upload FMEA Knowledge Sources

Upload specifications, standards, process flows, and historical data



Loaded 32 chunks from 9 files

<input type="checkbox"/>	Name
<input checked="" type="checkbox"/>	Characteristics Matrix.xlsx
<input checked="" type="checkbox"/>	Cross-Functional Team.xlsx
<input checked="" type="checkbox"/>	Customer Requirements (CRs CSRs).xl...
<input checked="" type="checkbox"/>	Design Inputs (from DFMEA).xlsx
<input checked="" type="checkbox"/>	Historical Data Lessons Learned.xlsx
<input checked="" type="checkbox"/>	Manufacturing Inputs.xlsx
<input checked="" type="checkbox"/>	Process Controls (Existing or Planned)...
<input checked="" type="checkbox"/>	Process Flow Diagram (PFD).xlsx
<input checked="" type="checkbox"/>	Regulatory Industry Requirements.xlsx

Generate FMEAs and then save or download

Generated FMEA Preview

	Process Step	Work Element	Potential Failure Mode	Potential Effect(s) of Failure	Severity	Potential Cause(s)	Occurrence	Current Controls	Detection	RPN	Recommended Action
0	6	Boiler joints	Joint torque out of spec or sealant bead missing/incomplete	External or internal leakage, pressure loss, failed leak pre-test, rework, possible custo	9	Incorrect torque application, torque tool drift, operator miss on sealant application, i	4	DC torque trace; UV vision; TQ-01 / 3 mo; Type-1; GR&R ≤10%; 1 In-station; stop & retc	3	108	Maintain torque tool calibrati
1	7	OPV setpoint	Relief pressure set outside 9.5-10.5 bar target or lock-nut not secured	Incorrect relief pressure, poor shot pressure performance, possible overpressure or w	8	Improper adjustment, master gauge error, lock-nut not tightened, paint mark missin	3	Reference master gauge; PG-01 / 6 mo; GR&R study; 1 at set; lock-nut; paint mark; re-	3	72	Standardize OPV adjustment i
2	8	Pump orientation	Pump isolation not installed or pump orientation not keyed/seated correctly	Assembly misfit, vibration/noise increase, possible hose routing issues, functional in	6	Operator misassembly, poka-yoke bypass, missing isolation component, incomplete	3	Visual poka-yoke; VIS-01 / N/A; WI audit; 1 In-station; halt; re-install; Control Plan CP-4	3	54	Improve visual standards for l
3	9	Flow meter orientation	Flow meter installed backwards or O-ring cut/rolled/missing	No or incorrect flow reading, leakage, brew performance failure, EOL leak failure, cus	8	Arrow direction not checked, O-ring damaged during assembly, poor part handling, i	4	Visual + leak test; VIS-02 / N/A; first-piece 100% visual; 1/10 leak; In-station; rework; re	4	128	Add stronger orientation visu:
4	10	Hose clamp engagement	Clamp band not positioned 1-2 mm from hose end or clamp not fully engaged	Leakage, hose loosening or blow-off, pressure loss, system leakage failure	9	Incorrect clamp placement, insufficient clamping, hose variation, operator error	4	Go/no-go gauge; GG-01 / 12 mo; Type-1; 1 In-station; re-clamp; replace hose; Control	3	108	Tighten standard work for cla
5	11	Ground bond resistance	Ground bond resistance above 0.1 ohm at 40 A	Electrical safety noncompliance, shock risk, IEC/UL failure, blocked shipment	10	Paint or contamination at bond point, poor fastener contact, missing hardware, dam	2	Ground bond tester; GB-40A / annual; R&R N/A (attribute); 1 EOL; rework bond; remo	2	40	Control paint-free bond locati
6	12	Thermistor contact	TIM missing/insufficient or thermistor torque out of spec	Incorrect temperature sensing, poor brew temperature control, group temperature o	8	Paste not applied, inadequate paste coverage, incorrect torque, tool variation, operat	4	UV vision + torque tool; VIS-03 / TQ-02; Attribute; GR&R torque; 1 In-station; reapply p	3	96	Strengthen UV verification for
7	14	Strain relief clamp	Clamp does not achieve specified pull strength	Cable movement or pull-out, stress on electrical connections, reliability issue, possib	8	Wrong insert, improper clamp installation, insufficient clamp force, component varia	3	Pull test fixture; PT-01 / 6 mo; Attribute; MSA app; Cell audit; rework clamp; change in	4	96	Audit insert selection, verify c
8	15	Firmware version	Incorrect firmware loaded, SN-to-FW mapping error, or CRC failure	Functional mismatch, unstable machine behavior, traceability error, blocked shipme	8	MES mapping logic error, wrong firmware selection, incomplete programming, corru	2	MES log + CRC test; MES / N/A; system validation; 1 EOL; block ship if mismatch; Cont	2	32	Maintain validated MES rules,
9	17	Pressure set	Flow pressure under load outside 9 bar ±1 bar	Shot pressure out of market spec, poor extraction performance, brew inconsistency, i	8	Calibration drift, incorrect pressure setting, pump or OPV variation, gauge error	4	Cal bench (master gauge); PG-01 / 6 mo; Type-1; GR&R ≤10%; 1 Cal; recalibrate; hold;	3	96	Review calibration process ca

[Download filled Excel template](#)

[Save to Cloud](#)

[Reset Session](#)

A	B	C	D	E
Process Step	Work Element	Potential Failure Mode	Potential Effect(s) of Failure	Severity
6	Boiler joints	Joint torque out of spec or sealant bead missing/incomplete	External or internal leakage, pressure loss, failed leak pre-test, rework, possible customer-visible leak	9
7	OPV setpoint	Relief pressure set outside 9.5-10.5 bar target or lock-nut not secured	Incorrect relief pressure, poor shot pressure performance, possible overpressure or weak extraction, calibration failure	8
8	Pump orientation	Pump isolation not installed or pump orientation not keyed/seated correctly	Assembly misfit, vibration/noise increase, possible hose routing issues, functional instability, downstream rework	6
9	Flow meter orientation	Flow meter installed backwards or O-ring cut/rolled/missing	No or incorrect flow reading, leakage, brew performance failure, EOL leak failure, customer leak complaint	8
10	Hose clamp engagement	Clamp band not positioned 1-2 mm from hose end or clamp not fully engaged	Leakage, hose loosening or blow-off, pressure loss, system leakage failure	9
11	Ground bond resistance	Ground bond resistance above 0.1 ohm at 40 A	Electrical safety noncompliance, shock risk, IEC/UL failure, blocked shipment	10
12	Thermistor contact	TIM missing/insufficient or thermistor torque out of spec	Incorrect temperature sensing, poor brew temperature control, group temperature out of 90-96 C range, performance drift	8
14	Strain relief clamp	Clamp does not achieve specified pull strength	Cable movement or pull-out, stress on electrical connections, reliability issue, possible safety concern	8
15	Firmware version	Incorrect firmware loaded, SN-to-FW mapping error, or CRC failure	Functional mismatch, unstable machine behavior, traceability error, blocked shipment, field performance issues	8
17	Pressure set	Flow pressure under load outside 9 bar ±1 bar	Shot pressure out of market spec, poor extraction performance, brew inconsistency, calibration hold	8
18	Group temp	Head temperature outside 90-96 C specification	Poor brew temperature, customer dissatisfaction, brew performance failure, requirement CR-002 not met	8
19-20	System leakage	Leak rate above limit or visible external leak during air decay/hot wet test	Water leakage, safety and reliability concerns, customer complaint, failure of CSR zero external leak requirement	10
21	Brew performance	Flow-time not approximately 60 ml/30 s or TDS outside target window	Poor cup quality, inconsistent extraction, customer dissatisfaction, market performance requirement miss	7
28	Noise level	SPL at 1 m exceeds 65 dBA ±2 dB window	Customer dissatisfaction, market spec failure, perceived poor quality	5
29	Traceability	Data incomplete; missing IDs, serial, firmware, or required fields in MES	Loss of traceability, inability to contain defects, packout block, CSR requirement failure	7

Assess the quality of FMEAs

FMEA Builder & Quality Assessor

[Generate FMEA](#) [Assess FMEA Quality](#) [My Documents](#) [How to Use](#)

Upload Completed FMEA(s)

Upload one or more filled FMEAs you want scored (xlsx, xls, csv, or pdf)

 PFMEA_...ro3000.xlsx  +
18.8KB



Loaded 1 spreadsheet file(s) with 34 rows

FMEA Builder & Quality Assessor

[Generate FMEA](#) [Assess FMEA Quality](#) [My Documents](#) [How to Use](#)

Upload Completed FMEA(s)

Upload one or more filled FMEAs you want scored (xlsx, xls, csv, or pdf)


 PFMEA_...ro3000.xlsx  +
18.8KB

Loaded 1 spreadsheet file(s) with 34 rows

Upload Scoring / Assessment Template(s) (Optional)

If no rubric is uploaded, the AI will autonomously assess FMEA quality using best-practice criteria.

Upload one or more rubrics or scoring templates (pdf, docx, txt, or xlsx) — optional

 Upload 200MB per file • PDF, DOCX, TXT, XLSX

Optional: Add focus areas (e.g., target severity thresholds, compliance references)

Score Uploaded FMEA

Reset Assessment

Assessment of the FMEA quality and improvements

Assessment Results

	Failure Mode	Risk Score	Completeness	Clarity	Severity Justification	Detection Adequacy	Improvement Actions
0	Pump below spec flow/pressure	63	Good	Good	Adequate	Adequate	Justify severity with customer impact threshold for brew performance complaints; add incoming test coverage rationale
1	Heater open/low wattage	58	Good	Good	Good	Adequate	Document why severity 8 applies versus potential safety escalation; convert sampled power draw verification to 100% te
2	Latent ESD damage	78	Adequate	Good	Needs improvement	Needs improvement	Clarify the specific end-user safety consequence behind severity 9 and separate functional reset from safety control loss i
3	Gasket degraded/contaminated	63	Good	Good	Adequate	Needs improvement	Add measurable storage limits for temperature, UV exposure, and shelf life; supplement visual checks with lot expiry syst
4	Under-torque causing micro-leak	83	Good	Good	Good	Adequate	Add explicit justification for occurrence based on torque tool capability and historical leak ppm; implement in-station pr
5	OPV set too high/low	79	Good	Good	Adequate	Adequate	Split over-pressure safety risk and under-pressure performance loss into separate failure modes or effects to better justif
6	Wrong orientation / missing isolators	55	Good	Good	Adequate	Needs improvement	Strengthen detection beyond visual/tug test with fixture-based orientation confirmation; document whether hose strain
7	Backward installation / O-ring nicked	64	Adequate	Good	Adequate	Adequate	Separate reversed installation from O-ring damage into distinct failure modes because causes and controls differ; add m
8	Coil not seated; reversed wires	58	Adequate	Good	Adequate	Adequate	Split coil seating and reversed wiring into separate rows with tailored occurrence and controls; verify keyed spades fully i
9	Clamp loose/not fully seated	84	Good	Good	Good	Adequate	Justify occurrence with tool wear and operator error data; validate end-of-line air leak test sensitivity for hot and cold lea

Download assessment report

Save to Cloud

Reset Assessment

Failure Mode	Risk Score	Completeness	Clarity	Severity Justification	Detection Adequacy	Improvement Actions
Pump below spec flow/pressure	63	Good	Good	Adequate	Adequate	Justify severity with customer
Heater open/low wattage	58	Good	Good	Good	Adequate	Document why severity 8 app
Latent ESD damage	78	Adequate	Good	Needs improvement	Needs improvement	Clarify the specific end-user s
Gasket degraded/contaminated	63	Good	Good	Adequate	Needs improvement	Add measurable storage limit
Under-torque causing micro-leak	83	Good	Good	Good	Adequate	Add explicit justification for o
OPV set too high/low	79	Good	Good	Adequate	Adequate	Split over-pressure safety risk
Wrong orientation / missing isolators	55	Good	Good	Adequate	Needs improvement	Strengthen detection beyond
Backward installation / O-ring nicked	64	Adequate	Good	Adequate	Adequate	Separate reversed installator
Coil not seated; reversed wires	58	Adequate	Good	Adequate	Adequate	Split coil seating and reversed
Clamp loose/not fully seated	84	Good	Good	Good	Adequate	Justify occurrence with tool w
Miswire; ground lug on paint	66	Adequate	Good	Good	Good	Split miswire and painted gro
Poor thermal contact / missing paste	68	Adequate	Good	Adequate	Needs improvement	Separate missing paste from p
Insufficient clamp / wrong cord OD	77	Adequate	Good	Good	Needs improvement	Increase detection from samp
Mislocated from heat source	79	Good	Good	Good	Needs improvement	Current visual template is we
Wrong/corrupt firmware	61	Good	Good	Adequate	Adequate	Clarify whether severity 8 incl
Cross-thread/stripped boss	51	Adequate	Good	Adequate	Needs improvement	Broaden effects if long-term l
Gasket pinch / panel warp	47	Adequate	Good	Needs improvement	Adequate	Separate cosmetic panel warp
Reservoir not latched / O-ring twist	54	Adequate	Good	Adequate	Needs improvement	Split latch failure and O-ring t
Transducer miscalibrated	57	Needs improvement	Adequate	Adequate	Needs improvement	The row is incomplete becaus